



MAS Certified Green® Certificate of Compliance Low-Emitting Materials

Awarded to:

AEROFLEX USA, INC., OF SWEETWATER, TN

282 INDUSTRIAL PARK ROAD; ZIP CODE: 37874



Category:
Cert. Scheme:

Construction Materials - Exterior/Interior** Adhesives, Glues, Sealants & Coatings
VOC Emissions

Accredited
Standards &
Test Methods:

California Dept. of Public Health Standard Method v1.2 *classroom & private office*

*Conforms
With:

LEED v4.1 ID+C, BD+C, Healthcare, Schools
CHPS 2019 Core Criteria 3.0 EQ C6.1.1
Criteria of MAS Certified Green® Program
TVOC Emissions at 14-days

*low-emitting materials
adhesives & sealants
low-emitting materials
0.5 mg/m³ or less*

Certified
Product:

Aeroseal LVOC™ Black Insulation Adhesive

Test Date:

August 6, 2020 Report No.:2000448 Certificate No.: MAS2000448-02R1-AR1



Testing Cert. # 2925.01
Product Cert. # 2925.02

Kevin Simpson Kevin Simpson
2021.01.25
17:43:12 -05'00'

Valid: August 2020 to August 2021

Product Certifier, MAS Certified Green CT

Laboratory Testing by **Materials Analytical Services, LLC** - ISO/IEC 17025:2017
3rd Party Product Certification by **MAS Certified Green®** - ISO/IEC 17065:2012

*outside of A2LA accreditation scope

**Compliance designation determined based on interior modeling scenarios and interior VOC Emissions guideline requirements.

3945 Lakefield Ct. · Suwanee, Ga. · 770-866-3206 · <http://www.mascertifiedgreen.com/>